Bozeman Water Treatment Plant Process Evaluation

By Cole Pampe, Ryan Thompson, and Seth Nims






Figure 1: Overview of water path through the BWTP

Backwash and ACH Dosing





Sludge Settling and Polymer Addition



Table 1: Raw sludge settling data

	L.S 1				L.S. 2				L.S. 3				L.S. 4			
Polymer (mg/L)	P/F	4 Min.	60 Min.	Sludge Cake	P/F	4 Min	60 Min	Sludge Cake	P/F	4 Min.	60 Min.	Sludge Cake	P/F	4 Min	60 Min	Sludge Cake
1					Fail	730	280									
2					Fail	560	250									
3					Pass	500	250	x					Fail	-	280	
4					Pass	440	250						Fail	-	280	
5	Pass	325	225	x	Pass	400	250		Pass	500	300	x	Pass	400	260	x
6	Pass	300	200	x	pass	360	250		Pass	500	300	x	Pass	330	280	
7	Pass	325	225						Pass	350	300		Pass	310	270	
8	Pass	300	200						Pass	425	315					
9	Pass	300	300						Pass	390	310					1
10	Pass	250	250						Pass	360	310					

Feasibility



ACH and Backwash

- Continued work with Montana State University
- Cost/benefit analysis of additional dosage
- Environmental Impacts
- Land application regulations

Polymer and Sludge Settling

- \$0.16 per day increase spent on polymer (figure
 4)
- \$5,111,197 (City Of Bozeman, 2021)
- Environmental impact

$$\frac{9000 \ gal}{day} * \frac{3.78541 \ L}{gal} * \frac{1 \ mg}{L} * \frac{1 \ lb}{453592 \ mg} * \frac{\$ \ 2.09}{lb} = \$ \ 0.16 \ per \ day$$

Bozeman Daily Chronicle (2017) Figure 4

References

Houghton, Katherine. Bozeman Daily Chronicle (2017). Bozeman Looks to Meet Increasing Water Demands

<u>https://www.bozemandailychronicle.com/news/city/bozeman-looks-to-meet-increasing-water-demands/article_e8856f74-e186-5f19-b556-f2b96a21a1f4.html</u>

City Of Bozeman. (2021)

Fiscal Year 2021 Approved Budget

https://weblink.bozeman.net/WebLink/DocView.aspx?

id=222975&dbid=0&repo=BOZEMAN&cr=1